

Maharaja Ranjit Singh Punjab Technical University, Bathinda

Name of Work:		Purchase of UPSs	
Sr. No.	Description of Item	Qty.	Unit
1	UPS (ONLINE 3 KVA):- On Line UPS with PWM technology, minimum backup of 30 minutes on Full Load (external batteries with minimum VAH 3024) ** Detailed Specs Attached	5	No's
2	UPS (ONLINE 6 KVA):- On Line UPS with PWM technology, minimum backup of 30 minutes on Full Load (external batteries with minimum VAH 4992) ** Detailed Specs Attached	49	No's
3	UPS (OFFLINE):- Offline / Line Interactive 1 KVA with 15 minutes backup ** Detailed Specifications of UPS • UPS using PWM Technology • IGBT based rectifier • Advanced DSP based technology • 0.8 Output PF • Double conversion efficiency up to 95% • ECO mode efficiency up to 98.5% • Input PF up to 0.99 • Input Thdi <5% • Protection : Over/Under Voltage at I/P Short Circuit & overload Lighting/Surge • High capacity battery charger • Dynamic design: Rack /Tower convertible • Integrated parallel load bus and synchronization port (LBS) • Easy site installation The UPS, in conjunction with a network interface card, shall be capable of gracefully shutting down one or more operating systems during when the UPS is on battery mode.	15	No's